



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599

www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

Acrysystems Laboratories, Inc.
101 North Prospect Street
Reading, PA 19606

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: AcryLabs 2100 Elastomeric Coating

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA No. 20-1224.02 and consists of pages 1 through 3.
The submitted documentation was reviewed by Rafael Macedo.

11/27/25

NOA No.: 24-1209.03
Expiration Date: 03/09/31
Approval Date: 11/27/25
Page 1 of 3



ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Cement-Adhesive-Coatings
Material: Elastomeric

SCOPE:

This approves “**AcryLabs 2100 Elastomeric Coating**” as a roof coating as described in this Notice of Acceptance, designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
PRI Construction Materials Technologies, Inc.	ALI-002-02-01	ASTM D6083 & TT-C-555B	02/15/17

MANUFACTURING LOCATION:

1. Reading, PA

PHYSICAL PROPERTIES OF COMPONENTS

Trade names: **AcryLabs 2100 Elastomeric Coating**

Thickness: Apply a Base Coat at a minimum rate of 1.5 gal/100 ft.² and a Finish Coat at a rate of 1.5 gal/100 ft.² for a minimum thickness of 20 dry mils.

Specifications: ASTM D 6083

Description: A waterborne 100% acrylic elastomeric roof and wall coating membrane for building applications. It is formulated for maximum adhesion to Galvanized Steel, Aluminum, Wood*, Concrete*, SPUF, EPDM, PVC, Granular SBS and Smooth BUR Roof Coverings.
*** Note: Application over these substrates shall not be as a roof system or a waterproofing system see Limitation #1.**

Container Size: 1, 5 and 55 gallons. Note all precautions on container.

Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly System’s Product Control Notice of Acceptance where it exceeds standards of this NOA.

NOA No.: 24-1209.03
Expiration Date: 03/09/31
Approval Date: 11/27/25
Page 2 of 3



LIMITATIONS

1. **AcryLabs 2100 Elastomeric Coating are not approved as and shall not be used as a Roof or Waterproofing System as required by the Florida Building Code Chapter 15 HVHZ.**
2. AcryLabs 2100 Elastomeric Coating shall only be used as a roof or exterior maintenance coating over the substrates specified herein in accordance with Chapter 15 of the Florida Building Code.
3. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire rating of this product.
4. **AcryLabs 2100 Elastomeric Coating** shall not be applied in inclement weather conditions.
5. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their roof assemblies Notice of Acceptance.
6. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test results shall be made available to Miami-Dade Product Control upon request.
7. Change in materials, use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
8. **AcryLabs 2100 Elastomeric Coating** shall be applied in accordance with manufacturer's published application instructions.
9. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.
10. The use of a reinforcing fabric in a maintenance coating is only to enhance the coating's ability to deliver efficient and long term performance through the protection of the underlying roof system and in this particular use does not become a roof system itself.
11. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



END OF THIS ACCEPTANCE



NOA No.: 24-1209.03
Expiration Date: 03/09/31
Approval Date: 11/27/25
Page 3 of 3